

# Rectangular ducts

OFI



## Description


Rectangular ducts are only used to supply air or extract from the premises and are not intended to use for the transport of solids in air. The products can be made of: galvanized steel sheet - corrosion class C3-L / C2-M; sheet with aluminium zinc coating - corrosion class C4-M / C3-H; stainless steel sheet AISI 304 (1.4301) or AISI 316L (1.4404) - corrosion class C5. Surfaces is made with reinforcement, stiffened with transverse trapezoid corrugations, resulting in low self-noise and greater resistance to pressure vibrations. Standard ducts joint tightness class B according to LST EN 1507. Products of higher tightness class C are also available on request. Ducts can be used at temperatures from -45 to +85 °C with appropriate insulation. The maximum permissible absolute humidity inside the air stream and outside is 18 g / kg. Protective films, that ensure cleanliness, are placed at the customer's request when ordering. For other dimensions and materials, please contact UAB „MKTechnika“ sales offices.

## Ordering code

Galvanized steel -	OFI500300-1500
AISI 304 - NP	
AISI 316L - 316NP	
Product	
Size	
Length	

Sample: NPOFI500300-1500 – made of stainless steel AISI 304 rectangular duct, dimensions WxH- 500x300 mm, length 1500 mm

## Dimensions



	W [mm]	H [mm]
Minimum dimension	100	100
Maximum standard dimension	2100	2100
Flange F20	Up to 1499	Up to 1499
Flange F30	1500-2100	1500-2100
Length of the duct L, mm	1500	

## Technical data

Large-sized ducts are internally reinforced with rods, single or cross joints.

Rectangular ducts can be ordered with a connection flange without flange, or with a ready flange but not connected.

Ducts flanges come with a sealing gel. The gel meets the requirements of VDI 6022 standard.

The pressure losses of the rectangular system are calculated using data from round ducts. Calculate the cross area and take the nearest smaller cross area of the circular duct.

Weight formula [kg] (galvanized steel)	W [mm]	H [mm]
$m[\text{kg}] = 14 \cdot (W[\text{m}] + H[\text{m}])$	Up to 1000	Up to 1000
$m[\text{kg}] = 16,4 \cdot W[\text{m}] + 16,6 \cdot H[\text{m}]$	From 1001 up to 1400	Up to 1000
$m[\text{kg}] = 16,7 \cdot (W[\text{m}] + H[\text{m}])$	From 1001 up to 1400	From 1001 up to 1400
$m[\text{kg}] = 19,4 \cdot W[\text{m}] + 19,7 \cdot H[\text{m}]$	From 1401 up to 2100	From 1001 up to 1400
$m[\text{kg}] = 20 \cdot (W[\text{m}] + H[\text{m}])$	From 1401 up to 2100	From 1401 up to 2100



# Rectangular ducts

## Technical data

When operating the duct system it is very important to observe the maximum allowable vacuum pressure. It varies depending on the size of the duct. Also, the stability of the entire system has a smooth and even duct surface that can be damaged during transportation or installation, which is why it is important to protect the ducts and other elements from damage. We recommend that you observe the maximum allowable pressures Pa in the table when selecting the duct system. For pressures close to the critical limit, we recommend the use fine ducts to prevent possible duct compression or swelling in the system.

Maximum allowable system pressure [Pa]	W [mm]	H [mm]
1000	Up to 1000	Up to 1000
1000	From 1001 up to 1400	Up to 1000
1300	From 1001 up to 1400	From 1001 up to 1400
1500	From 1401 up to 2100	From 1001 up to 1400
1500	From 1401 up to 2100	From 1401 up to 2100